Chelsea, Ma.

NO. 6 FUEL OIL/BUNKER FUEL

Lab Reference	2006-0007	Classification	Tank 2
Vessel/Barge	Texas	Grade	#6 Fuel Oil
Client	Sprague Energy	Terminal	Portsmouth, NH
Date on Sample	1/10/06	Sampled by	KA
Date Tested	1/10/06	Tested by	AC/RG
Allocations		Lab Overtime	

Tests	Method	Results	Unit of Measure
API Gravity @ 60°F	D-4052	13.6	API
Flash Point, PMCC	D-93B	230+	Degrees F
Pour Point/Upper	D-97	0/32	Degrees C/F
Sulfur Content	D-4294	0.983	Weight %
S&W Content	D-1796	0.10	Volume %
Viscosity @ 122F	D-445	254.6	Cst
Viscosity @ 122F	D-2161	120.3	Sfs
Ash Content	D-482	0.025	Weight %
Heat of Combustion	D-240	18,621	Btu/lb
Gravity	Table 8	8.121	lb./gal
Heat of Combustion	D-240	151,221	Btu/Gal.
Nitrogen	D-5762	0.34	Weight %
Vanadium	D5863B	33	Ppm
Sodium	D5863B	8	Ppm
Water by Distillation	D-95	0.10	Volume %
Sediment by Extraction	D-473	0.05	Weight %
Asphaltenes	D-3279	3.9	Weight %
Conradson Carbon Residue	D-189	10.2	Weight %

Sample	Tests	Method	Results	Unit of Measure
Upper	Sulfur Content	D-4294	0.979	Weight %
Middle	Sulfur Content	D-4294	0.975	Weight %
Lower	Sulfur Content	D-4294	0.983	Weight %

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS
REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE
TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE.
THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF
ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON
A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE
CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER
PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY
BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF
MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY
SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE
AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES
THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.

Approved by_____

Albert Collin Jr.